



Date.....3/22/83.....Permit No. 73-28**TOWN OF ACTON****APPLICATION FOR PERMIT TO CONSTRUCT WITHIN A PUBLIC WAY**

This application must be submitted not less than five (5) days prior to any Construction within a public way.

Notice 24 hours in advance of any construction must be given to the Town Engineer.

1. Permittee: LEON E THOMPSON Address: 477 LIBERTY SQ RD, BAYBOR
2. Location of Proposed Construction: 32 WASHINGTON DR
3. Purpose of Construction: DRIVEWAY
4. Length of Cut: 15'
5. Width of Cut: 8'
6. Width of Existing Pavement: 24'
7. Type of Existing Roadway Surface: HOT TOP Type of Curb: CAPE COD
8. Type of Existing Sidewalk Surface: NONE Type of Shoulder: GRASS
9. Date of Street Opening: From..... To.....

I, the undersigned, hereby declare that I have read and agree to the Town of Acton Specifications for Regulating Construction with Public Ways dated February 4, 1969. I have deposited the required bond with the Town of Acton, and I covenant and agree that the Town may deduct from this amount the cost of repairs to the road surface, curbs, shoulders, walls or other features within the right-of-way including replacing bounds if not completed by me to the satisfaction of the Town Engineer within the specified time.

Witness my hand and seal,

Signature of Applicant.....

Special Instructions:

INSPECTION 11-15-83 D.A. E.D.H.

DRIVE PAVED O.K.

PATCH S.W. ? & SWEEP

SHOULDER FAIR

RAKE STRIP

BND. END. O.K.

INSPECTION 8-13-86 D.R. & T.W.

BND END OK

SHOULDER OK

S.W. GOOD

DRIVE OK

Permit Issued: Date APRIL 19, 1983 By: D. Allen



Application Denied: Date..... By:.....

Work Inspected and Approved: Date AUG. 13, 1986 By: D. Allen

TOWN OF ACTON TRENCH DETAIL FEB. 1969 NO SCALE

SKETCH

SECTION A-A



NOTE: 1. FINAL PATCH DEPTH
2. SEE SPECIFICATIONS FOR
3. OIL TREATED ROADS
4. BIT. CONC. ROADS
FURTHER REQUIREMENTS

NOTE: LINE AND GRADE
OF SIDEWALK SHALL
BE UNDISTURBED BY
DRIVEWAY

Date: March 22, 1983

FROM: Engineering Department

TO: Town Treasurer

SUBJECT: Bond-Permit to Construct Within a Public Way

Please hold the enclosed Bond in the form of:

Certified Check # 04133075702 Bank Cooperative Bank of Concord

Pass Book # _____ Bank _____

Other (Specify) _____

in the amount of \$250.00 from (Applicant) Leon E. Thompson

as security for "Permit to Construct Within a Public Way" # 83-28

located at 22 Washington Drive; for authority

see Section IV-A, Specifications for Regulating Construction Within

Public Ways. This bond is to be held until released in writing by

this department.

Signed: David Albert
Asst. Town Engineer

DMV

WASHINGTON

D.

150.00' S.W. DE

12' ECP

ECONOMIC
EASEMENT

PROPOSED DRIVEWAY

FUTURE
EXPANSION

PROPOSED
BED ROOM
FIRST
ELEV. 90.0'

HOUSE
FLOOR

N/A MEWER

70

FLOR

PLAINS

EDGE VEGETATED

WETLAND

LOT 366



FILE COPY

TOWN OF ACTON
ENGINEERING DEPARTMENT

March 24, 1983

Leon E. Thompson
422 Liberty Square Road
Boxborough, MA. 01719

Re: Driveway Permit #83-28

Dear Mr. Thompson;

I have reviewed your driveway permit application for 22 Washington Drive and noticed that the proposed driveway grade is in excess of the Town recommended maximum of 15% (a 15 foot change of grade in 100 feet). By scaling from the proposed plot plan included with the building permit application it appears to be about 20%. This is a very steep grade for winter conditions.

Please consider revising your proposed plans in order to reduce the steepness of this driveway.

Very truly yours,

Ralph W. Herrick

Ralph W. Herrick
Town Engineer

RWH:nc
cc: Building Commissioner
0014N/0001N

STON

DRIVE

4x43

225x54

C.B.
RIM=225.67

SIDEWALK

150.00'

225x54

126

4" LOAM & SEED

EXISTING SEPTIC
SYSTEM
LOCATION APPROX.
(SEE REFERENCE PLAN)

FIELD
LOCATED
EXISTING
SEPTIC
TANK

PROPOSED
INV=212.26

4" C.I.
L=18'
S=020

29'-4"
GARAGE
FLOOR=
214.92

ROOFED
DECK

210

45'-0"

4" INV=212.62

F.F. = 216.0 ±

B.F. = 207.42 ±

69'-0"

DRIVE

WOOD CHIP / BARK MULCH SLOPE

CONC.
SPILLWAY

HAYBALES AT TOE OF SLOPE

100 YR. FLOOD ELEVATION
198.0 - 197.5

193x6

192x9

TOWN OF AUSTON

ENGINEERING DEPARTMENT

DATE: NOV. 15, 1983

TO: LEON THOMPSON

SUBJECT: Notice of Inspection - Permit to Construct Within a Public Way # 83-28

LOCATION: LOT 366 WASHINGTON DRIVE

The following work remains to be done:

(1) SWEEP SIDEWALK & PATCH HOLE
AT WATER SERVICE

(2) RAKE & SEED GRASS STRIP
BETWEEN SIDEWALK & ROAD.

Please contact us when the work is completed.

Signed D. A.

Assistant Town Engineer

TOWN OF ACICHI

ENGINEERING DEPARTMENT

DATE: 12/6/83

TO: Leon Thompson

SUBJECT: Notice of Unexp. Permit to Construct Within a Public Way # 83-28

LOCATION: Lot 366 Washington Drive

The following work remains to be done:

- 1) Sweep sidewalk and patch hole at water service.
- 2) Rake and seed grass strip between sidewalk and road

Please contact us when the work is completed.

Signed [Signature]
Asst. Town Engineer

Date: 8/14/86

FROM: Engineering Department

TO: Town Treasurer

SUBJECT: Bond - Permit to Construct Within a Public Way

Please release the bond in the form of:

Certified Check # 04133075702 Bank Reserve Bank of Canada

Pass Book # _____ Bank _____

Other (Specify) _____

in the amount of \$250.00 to Les P. Thompson

which is being held as security for "Permit to Construct Within
a Public Way" # 83-28, Located at 22 Washington St

for authority see Section II - A specification for regulation of
construction within public ways.

Work proposed under this permit has been satisfactorily completed.

Signed: Daniel Albert

Mail to:
422 Liberty Sq. Rd.
Bayboro.

